

August 12, 2014

CERTIFIED MAIL

Mr. Charles R. Mundy
SANTA CLARA WASTE WATER
2775 N. Ventura Rd. Ste 209
Oxnard, CA 93030

Subject: **NOTICE OF VIOLATION – SANTA CLARA WASTEWATER
(Industrial Wastewater Permit #OC-8)**

Dear Mr. Mundy:

Based on a review of your company's Self-Monitoring Report (SMR) and analytical data collected by Technical Services Program-Source Control (TSP-SC) staff for the month of June 2014, Technical Services Program-Source Control (TSP-SC) staff have determined that your company failed to comply with the conditions/requirements of its Industrial Wastewater Discharge Permit (Permit) and Chapter 19, Section 19-26 of the Oxnard City Code. The violation of Biochemical Oxygen Demands (BOD) is detailed below:

DATE OF VIOLATION	SOURCE OF DATA	PARAMETER	REPORTED VALUE	DISCHARGE LIMIT
06/12/14	TSP-SC	BOD	1400 mg/L	800 mg/L

Using the flow from the month of June staff have calculated the total pounds of BOD at 2538.71 pounds discharged from the 12th through 13th of June 2014. Of that amount 1450.69 pounds were allowable loading for BOD. TSP-SC staff have calculated the excessive strength charges to be \$534.16 (see below). These charges are payable upon receipt of the City's invoice.

Parameter	Total lbs.	Allowable lbs.	Excess lbs.
BOD	2538.71	1450.69	1088.02
Total Charge	$(1.08802 \times \$490.95) = \534.16		

At this time TSP-SC staff are in receipt of your letter of explanation for this violation of BOD, and no further information is required. Please continue to take the necessary steps to ensure that all Permit conditions/requirements are complied with in the future.

If you have any questions, please contact Mr. John Talmage, Wastewater Environmental Specialist, at (805) 385-3960.

Jeremy Grant
Wastewater Environmental Specialist